


CERTIFICATE

Certified Passive House Component

Component-ID 0945wi04 valid until 31st December 2024

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany




Category: **Window Frame**
Manufacturer: **PROFINE IBERIA S.A. UNIPERSONAL
- SISTEMAS KÖMMERLING,
Camarma de Esteruelas,
Spain**
Product name: **KÖMMERLING 76**


**This certificate was awarded based on the following
criteria for the warm, temperate climate zone**

Comfort $U_W = 0.99 \leq 1.00 \text{ W}/(\text{m}^2 \cdot \text{K})$
 $U_{W,\text{installed}} \leq 1.05 \text{ W}/(\text{m}^2 \cdot \text{K})$
with $U_g = 0.90 \text{ W}/(\text{m}^2 \cdot \text{K})$

Hygiene $f_{Rsi=0.25} \geq 0.65$



warm, temperate climate



**CERTIFIED
COMPONENT**

Passive House Institute

Passive House
efficiency class

phE


phD

phC

phB

phA

www.passivehouse.com



Description

Construction: PVC-windowframe with steel-reinforcements inside the sash and insulation fillings (0.031 W/(mK)) inside the blind frame. Pane thickness: 49 mm (4/18,5/4/18,5/4), rebate depth: 18 mm, spacer: SWISSPACER Ultimate

Explanation

The window U-values were calculated for the test window size of 1.23 m × 1.48 m with $U_g = 0.90 \text{ W}/(\text{m}^2 \cdot \text{K})$. If a higher quality glazing is used, the window U-values will improve as follows:




Glazing	$U_g =$	0.90	0.70	0.64	0.58	$\text{W}/(\text{m}^2 \cdot \text{K})$
		↓	↓	↓	↓	
Window	$U_W =$	0.99	0.86	0.81	0.77	$\text{W}/(\text{m}^2 \cdot \text{K})$





Transparent building components are classified into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge, and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components which have been certified for climate zones with higher requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on www.passivehouse.com and passipedia.org.

Validated installations

Exterior insulation and finishing system		Ventilated facade (fixed glazing)		Cavity wall	
$U_{Wall} = 0.23 \text{ W}/(\text{m}^2 \cdot \text{K})$		$U_{Wall} = 0.23 \text{ W}/(\text{m}^2 \cdot \text{K})$		$U_{Wall} = 0.22 \text{ W}/(\text{m}^2 \cdot \text{K})$	
					
$\Psi_{install}$	$\text{W}/(\text{m} \cdot \text{K})$	$\Psi_{install}$	$\text{W}/(\text{m} \cdot \text{K})$	$\Psi_{install}$	$\text{W}/(\text{m} \cdot \text{K})$
Top	0.003	Top	0.003	Top	0.006
Side	0.003	Side	0.003	Side	0.006
Bottom	0.014	Bottom	0.013	Bottom	0.013
$U_{W,installed} = 1.01 \text{ W}/(\text{m}^2 \cdot \text{K})$		$U_{W,installed} = 1.01 \text{ W}/(\text{m}^2 \cdot \text{K})$		$U_{W,installed} = 1.01 \text{ W}/(\text{m}^2 \cdot \text{K})$	

Frame values			Frame width b_f mm	U -value frame U_f $\text{W}/(\text{m}^2 \cdot \text{K})$	Ψ -glazing edge Ψ_g $\text{W}/(\text{m} \cdot \text{K})$	Temp. Factor $f_{Rsi=0.25}$ [-]
Mullion 1 casement	(1M1)		162	1.20	0.024	0.69
Bottom	(OB1)		116	0.98	0.027	0.72
Top	(OH1)		116	0.98	0.027	0.72
Lateral	(OJ1)		116	0.98	0.027	0.72
Spacer: SWISSPACER Ultimate			Secondary seal: Polysulfide			

